DX3 Series
Insert Manual

For complete installation instructions, see the Tube Heater General Manual that accompanies this insert manual.

The DX3 Series Infrared Tube Heater is a positive pressure, single-stage radiant heater system. This insert manual is a supplement to the Tube Heater General Manual and provides specific information related to the DX3 Series model. All persons involved with the installation, operation and maintenance of the heater system must read and understand the information in this insert manual and the accompanying Tube Heater General Manual.

⚠ WARNING



Improper installation, adjustment, alteration, service or maintenance can cause property damage, injury or death. Read the installation, operation and maintenance instructions thoroughly before installing or servicing this equipment.

This heater must be installed and serviced by trained gas installation and service personnel only. Failure to comply could result in personal injury, asphyxiation, death, fire or property damage.



In locations used for the storage of combustible materials, signs must be posted to specify the maximum permissible stacking height to maintain the required clearances from the heater to the combustibles. Signs must either be posted adjacent to the heater thermostats or in the absence of such thermostats, in a conspicuous location.



Not for residential use! Do not use this heater in the home, sleeping quarters, attached garages, etc. Installation of a commercial tube heater system in residential indoor spaces may result in property damage, serious injury, asphyxiation or death.

For Your Safety

If you smell gas:

- Do not try to light any appliance.
- Do not touch any electrical switch.
- Do not use any phone in your building.
- Immediately call your gas supplier from a neighbor's phone.
- Follow the gas supplier's instructions.
- If you cannot reach your gas supplier, call the fire department.

Keep these instructions for future reference.

LIODX3-Rev.13012
1M-8/12(CDS)
Replaces: LIODX3-1M-8/10(CDS)

Contents

1.0 Safety 3
Safety Labels and Locations 3
Clearance to Combustibles 4
2.0 Installation 6
Gas Requirements 6
Electrical Requirements. 6
Wiring 7
Specifications 10
Tube Installation Sequence 11
3.0 Operation 12
Sequence of Operation 12
Thermostat 12
Operational Indicator Lights. 13
4.0 Troubleshooting Guide 14
5.0 Parts 18
Components 18
Parts List 18
Kit Contents Check List 20
Approvals. 20
Limited Warranty 20

NOTE: See page 10 for a list of available models and specifications.


1.0 Safety

Read and understand all safety information and warnings in this insert manual and the Tube Heater General Manual before installation, operation and maintenance of the radiant tube heater system.


Safety Labels and Their Locations

Product safety signs or labels should be replaced by the product user when they no longer are legible. Contact either your local distributor or the product manufacturer for obtaining replacement signs or labels.


F/N: LLV3EP1




F/N: LLV3EP5
(Models with 24VAO Option)



F/N: LLV3EP6






Back Panel





F/N: LLAC
Air Metering Orifice




F/N: LLTB018 (Natural Gas)
F/N: LLTB019 (LP Gas)


Top Panel





F/N: LLTCL001L/C/R
Clearance to Combustibles Labels





F/N: LLLOGO1 Logo Label

SERVICE ACCESS PANEL
IGNITER & FLAME SENSE COMPARTMENT
1. Turn off gas & electricity.
2. Remove cover by lifting top cover upward and outward.

CAUTION: HOT SURFACE.
KEEP COVER IN PLACE. REMOVE FOR SERVICE ONLY.

F/N: LLTB026

SERVICE ACCESS PANEL
CONTROLS & GAS VALVE COMPARTMENT
1. Disconnect gas & electricity.
2. Remove four (4) thumbscrews.
3. Remove top cover.
4. Swing hinged panel downward.

KEEP COVER IN PLACE. REMOVE FOR SERVICE ONLY.

F/N: LLTB024L

DX-40-125N(-3) **Serial No.:** 0804XXXXXXXXX 0001

Production Code: DX3-125 **Stock:** None
Version: 7.08 **Add-On:** N/A

Data on this label is for the model shown on this label. If your heater has been converted, this information is not accurate. Please contact the factory for assistance.

BURNER COMPONENTS: (Specify TP-#'s)


Gas Valve:	36G54-224-N	840A	Diag. Light:	50	Circuit Board
Circuit Board:	35-66	851B	Term. Block:	None	N/A
Wire Harness:	3 PCS Harness	325J	Trans.:	40 VA	826
N.O. Switch:	None	N/A	Fan:	Fasco Lg.	55A
N.O. VL Orifice:	None		Blower:	50Hz - 120V	55B
N.C. Switch:	None	N/A	Alt. Fan Usage:	When Specified	
N.C. VL Orifice:	None		Relay:	Picker x2	1325
Diff Switch:	IS2201003		Filter:	None	N/A
Diff VL Orifice:	Gray (+/-		24 Volt In:	3 T-plug	852
Ignitor:	Norton	50	120 Volt In:	6' Blk. Cord	333
Burner:	Mid	201B	Gas In:	7/8" FC	83
16" Tube:	4" Gen.	380	Extra VL Orifice:	None	
Ind. Lights:	Yellow - 24V	828			

HEATER TYPE:	Orifice Type:	C1	C2	C3	Internal Use Only:		
C1	Gas: TP-204#	19	19	19	Electric: LLWT038	Special 1:	17
	Air: TP-44#	1 5/16"	1 7/16"	1 5/16"	Tag: None	Special 2:	1 7/16"

For parts replacement information, contact factory at 586-756-0950 or visit www.drp-co.com/parts.

SAMPLE

Burner Control Box Component Label
(located inside the center compartment lid)



Controls Compartment

RE-VERBER-RAY **RE-VERBER-RAY INFRA-RED RADIANT TUBE HEATER**
FOR OUTDOOR USE AND INDOOR (Non-Residential) INSTALLATION ONLY.
Class II/A Permanent Label

MODEL NO.	INPUT BTU/H	FOR USE WITH
DX-40-125N(-3)	125,000	Natural Gas
Volts AC: 120V - 60Hz	**Manifold Pressure:** 3.5 in. W.C.P.	**Heater Type** C1
AMPS - Starting: 4.8	**Maximum Inlet Pressure:** 14 in. W.C.P.	**Minimum Mounting Angle:** 0 DEGREES
AMPS - Running: 1.1	**Minimum Inlet Pressure:** 5 in. W.C.P.	**Maximum Mounting Angle:** 45 DEGREES
Combustion Chamber: 4" Black Coated Aluminized	For stainless steel upgrades: The combustion tube is 409 Series stainless steel.	

DESIGN COMPLIES WITH:
ANSI Z83.20b-2004-GAS FIRED LOW INTENSITY INFRA-RED HTR.

DETROIT RADIANT PRODUCTS COMPANY **Serial No.:** 0807XXXXXXXXX 0001
21400 HOOVER ROAD - WARREN, MI
(586) 756-0950 - www.drp-co.com

SAMPLE


Rating Plate

SERVICE ACCESS PANEL
FAN COMPARTMENT
1. Disconnect gas & electricity.
2. Remove top cover (2 thumbscrews).
3. Remove six (6) 1/4" screws.
4. Lift and remove panel.

KEEP COVER IN PLACE. REMOVE FOR SERVICE ONLY.

F/N: LLTB025R

16" Burner Tube **Combustion Chamber** **Radiant Tube(s)**



Fan Compartment

⚠ DANGER

Avoid Serious Injury, Death or Property Damage.
Maintain Clearances to Combustible to Prevent the Risk of Fire.

Clearance to combustibles must be maintained at all times in order to prevent the ignition of combustible materials. In locations used for the storage of combustible materials, signs must be posted to specify the maximum permissible stacking height to maintain the required clearances from the heater to the combustibles. Signs must either be posted adjacent to the heater's thermostats or in the absence of such thermostats, in a conspicuous location. Clearances are provided on the heater's safety label and in the heater's Installation, Operation and Maintenance manual. Product installation and operation must comply with applicable standards, codes and regulations. Post this tag adjacent to the heater's thermostat or controls before operating the heater.

- INSTALLER: READ AND POST THIS NOTICE -

F/N: LL01 - Clearance Safety Tag
(Affix adjacent to heater's thermostat)

⚠ INSTALLER

AVOID EQUIPMENT FAILURE

THIS 10 FT. TUBE IS THE COMBUSTION CHAMBER.

The combustion chamber utilizes either 409 stainless, titanium alloy or aluminized steel - depending on the model number of your heater.

THIS TUBE MUST BE THE FIRST TUBE FOLLOWING THE BURNER CONTROL BOX.

Rotate the tube's welded seam to bottom.
Consult the manual(s) for further details.

F/N: LLTB004 (orange)
(150,000 - 200,000 Btu/h models only)

Clearance to Combustibles

⚠ WARNING



Placement of explosive objects, flammable objects, liquids and vapors close to the heater may result in explosion, fire, property damage, serious injury or death. Do not store or use explosive objects, liquids or vapor in the vicinity of the heater.


Clearance to combustibles is defined as the minimum distance that must exist between the tube surface, or reflector, and any combustible items (see Figure 1.1). It also pertains to the distance that must be maintained from moving objects around the tube heater. When installing the tube heater system, clearances to combustibles for the model tube heater and configuration must be maintained. Refer to Chart 1.1 to determine the required distances for your model.

Chart 1.1 • **Clearance to Combustibles in Inches** (see Figure 1.1 for Mounting Angles)

Model Number	Mounting Angle*	Side		Top	Below
		Front	Behind		
DX3 (20, 30, 40) - 50, 60 [N, P]	0°	9	9	6	47
	45°	39	8	10	47
with 1 side shield	0°	29	8	6	47
with 2 side shields	0°	9	9	6	47
20 ft. from burner	0°	7	7	6	30
DX3 (20, 30, 40) - 75 [N, P]	0°	9	9	6	60
	45°	39	8	10	60
with 1 side shield	0°	29	8	6	60
with 2 side shields	0°	9	9	6	60
20 ft. from burner	0°	7	7	6	30
DX3 (30, 40, 50) - 100 [N, P]	0°	14	14	6	66
	45°	39	8	10	66
with 1 side shield	0°	29	8	6	66
with 2 side shields	0°	16	16	6	66
20 ft. from burner	0°	7	7	6	30
DX3 (30, 40, 50, 60) - 125 [N, P]	0°	20	20	6	76
	45°	58	8	10	76
with 1 side shield	0°	42	8	6	76
with 2 side shields	0°	20	20	6	76
20 ft. from burner	0°	7	7	6	30
DX3 (40, 50, 60) - 150 [N, P]	0°	24	24	6	81
	45°	58	8	10	81
with 1 side shield	0°	42	8	6	81
with 2 side shields	0°	23	23	6	81
20 ft. from burner	0°	11	11	6	44
DX3 (40, 50, 60, 70) - 175 [N, P]	0°	34	34	6	92
	45°	63	8	10	92
with 1 side shield	0°	50	8	6	92
with 2 side shields	0°	30	30	6	92
20 ft. from burner	0°	11	11	6	44
DX3 (50, 60, 70, 80) - 200 [N, P]	0°	41	41	6	94
	45°	63	8	10	94
with 1 side shield	0°	54	8	6	94
with 2 side shields	0°	30	30	6	94
20 ft. from burner	0°	11	11	6	44

*Heaters mounted on an angle between 0° to 45° must maintain clearances posted for 0° or 45°; whichever is greater. The stated clearance to combustibles represents a surface temperature of 90°F (32°C) above room temperature. Building materials with a low heat tolerance (such as plastics, vinyl siding, canvas, tri-ply, etc.) may be subject to degradation at lower temperatures. It is the installer's responsibility to assure that adjacent materials are protected from degradation.

Figure 1.1 • **Mounting Angles**



2.0 Installation

⚠ WARNING



Improper installation, adjustment, alteration, service or maintenance can cause property damage, serious injury or death. Read and understand, the installation, operating and maintenance instructions thoroughly before installing or servicing this equipment. Only trained, qualified gas installation and service personnel may install or service this equipment.

Not for residential use! Do not use this heater in the home, sleeping quarters, attached garages, etc. **Installation of a commercial tube heater system in residential indoor spaces may result in property damage, serious injury or death.**

Instructions for the following are detailed in the Tube Heater General Manual:

- Design considerations
- Hanger suspension and placement
- Tube layout and assembly
- Burner control box suspension
- Reflectors (and accessories)
- Venting and combustion air intake
- Gas requirements
- Baffle assembly

Note: Electronic versions of all manuals are available at www.detroitradiant.com

Gas Requirements

Type of Gas	Required Manifold Pressure	Minimum Inlet Pressure	Maximum Inlet Pressure
Natural	3.5 Inches W.C.	5.0 Inches W.C.	14.0 Inches W.C.
Liquefied Petroleum	10.0 Inches W.C.	11.0 Inches W.C.	14.0 Inches W.C.



IMPORTANT: Consult the Tube Heater General Manual for gas connection requirements.

Electrical Requirements

- 120VAC - 60 Hz GRD, 3-wire.
- 120VAC thermostat connection.
- Starting current 4.8 amps
- Running current 1.1 amps

NOTICE

The DX3 Series comes standard requiring a 120VAC thermostat connection. An optional 24VAC internal relay (24VAO) may be factory installed if the heater is to be controlled via a 24VAC thermostat. A 40VA transformer is necessary when using the 24VAO option.

NOTE: A relay transformer may be used in lieu of the factory installed 24VAO option.


Wiring

⚠ WARNING


Electric Shock
Field wiring to the tube heater must be connected and grounded in accordance with national, state, provincial, local codes and to the guidelines in the Tube Heater General Manual and Series Insert Manual. In the United States refer to the most current revisions to the ANSI/NFPA 70 Standard and in Canada refer to the most current revisions to the CSA C22.1 Part I Standard.

Figure 2.1 • Field Wiring Diagrams

A. 120V Single/Multiple Line Voltage Heater(s)



B. 24VAO (Internal Relay Option)




Before field wiring this appliance - Check existing wiring; replace if necessary.

Note: If any of the original wire supplied with the appliance must be replaced, it must be replaced with wiring material having a temperature rating of at least 105° C.

Figure 2.2 • Internal Wiring Diagrams

A. Ladder Diagram - TP-351A



B. Block Diagram - TP-351A






Figure 2.3 • Alternative Wiring Diagrams

A. TP-351A Ladder Diagram - Internal Relay Option (24VAO)



B. TP-351A Block Diagram - Internal Relay Option (24VAO)



Specifications

Chart 2.1 • Specifications

Model Number	Gas Type (Select One)	BTU/H	Straight Length	U-Tube Length	Standard Weight (lbs.)	Stainless Steel Weight (lbs.)	Recommend Mounting Height	Combustion Chamber (Black Coated)	Radiant Emitter Tube(s) (Black Coated)	Radiant Surface Area (sq. ft.)	36" Baffle Quantity
DX3-20-50	N or LP	50,000	21'-9"	13'-1"	120	N/A	9' to 15'	Alum	Alum	20.2	5
DX3-20-60	N or LP	60,000	21'-9"	13'-1"	120	N/A	10' to 15'	Alum	Alum	20.2	5
DX3-20-75	N or LP	75,000	21'-9"	13'-1"	120	145	11' to 18'	Alum	Alum	20.2	5
DX3-30-50	N or LP	50,000	31'-5"	**17'-9"	160	N/A	10' to 15'	Alum	Alum	30.4	5
DX3-30-60	N or LP	60,000	31'-5"	**17'-9"	160	N/A	11' to 18'	Alum	Alum	30.4	5
DX3-30-75	N or LP	75,000	31'-5"	**17'-9"	160	195	12' to 20'	Alum	Alum	30.4	5
DX3-30-100	N or LP	100,000	31'-5"	**17'-9"	160	195	13' to 23'	Alum	Alum	30.4	5
DX3-30-125	N or LP	125,000	31'-5"	**17'-9"	160	195	14' to 25'	Alum	Alum	30.4	6
DX3-40-50	N or LP	50,000	41'-1"	22'-9"	190	N/A	11' to 18'	Alum	Alum	40.5	5
DX3-40-60	N or LP	60,000	41'-1"	22'-9"	190	N/A	11' to 18'	Alum	Alum	40.5	5
DX3-40-75	N or LP	75,000	41'-1"	22'-9"	190	235	12' to 20'	Alum	Alum	40.5	4
DX3-40-100	N or LP	100,000	41'-1"	22'-9"	190	235	13' to 23'	Alum	Alum	40.5	4
DX3-40-125	N or LP	125,000	41'-1"	22'-9"	190	235	14' to 25'	Alum	Alum	40.5	5
DX3-40-150	N or LP	150,000	41'-1"	22'-9"	190	235	15' to 27'	Titan	Alum	40.5	5
DX3-40-175	N or LP	*175,000	41'-1"	22'-9"	190	235	16' to 30'	Titan	Alum	40.5	5
DX3-50-100	N or LP	100,000	50'-9"	**27'-5"	235	290	15' to 27'	Alum	Alum	50.6	2
DX3-50-125	N or LP	125,000	50'-9"	**27'-5"	235	290	15' to 27'	Alum	Alum	50.6	3
DX3-50-150	N or LP	150,000	50'-9"	**27'-5"	235	290	16' to 30'	Titan	Alum	50.6	3
DX3-50-175	N or LP	*175,000	50'-9"	**27'-5"	235	N/A	17' to 35'	Titan	Alum	50.6	3
DX3-50-200	N or LP	*200,000	50'-9"	**27'-5"	235	N/A	18' to 40'	Titan	Alum	50.6	2
DX3-60-125	N or LP	125,000	60'-5"	32'-5"	265	330	16' to 30'	Alum	Alum	60.7	2
DX3-60-150	N or LP	150,000	60'-5"	32'-5"	265	330	17' to 35'	Titan	Alum	60.7	2
DX3-60-175	N orLP	*175,000	60'-5"	32'-5"	265	N/A	17' to 35'	Titan	Alum	60.7	2
DX3-60-200	N or LP	*200,000	60'-5"	32'-5"	265	N/A	18' to 40'	Titan	Alum	60.7	2
DX3-70-175	N or LP	*175,000	70'-1"	**37'-3"	300	N/A	19' to 42'	Titan	Alum	70.9	2
DX3-70-200	N or LP	* 200,000	70'-1"	**37'-3"	300	N/A	19' to 42'	Titan	Alum	70.9	2
DX3-80-200	N or LP	* 200,000	79'-9"	42'-1"	330	N/A	20' to 45'	Titan	Alum	81.0	2

* Model requires stainless steel tube clamp (P/N: TP-220) to be located at the seam between the primary combustion chamber and the secondary combustion tube downstream of the burner control box.
** Model requires 5EA-SUB accessory package when installing in a 'U' configuration (P/N: TF1B).


IMPORTANT: Reference box label to determine the number of required baffles sections for each model heater.

Titan = Black coated titanium stabilized aluminized steel.
Alum = Black coated aluminized treated steel.

Tube Installation Sequence

Figure 2.4 • Tube Installation Sequence

Important! The combustion chamber & radiant tube sections must be installed in the following order.



Key

- Burner Control Box with 16-inch Burner Tube
- Black Coated Combustion Chamber Tube*
- Black Coated Aluminized Combustion Chamber/Radiant Emitter Tube
- Standard Tube Clamp
- Stainless Steel Tube Clamp (P/N: TP-220)
  175-200 MBH models only - Located between 1st and 2nd 10 ft. tube sections.
- Baffle Location

*Aluminized tubes (50,000 to 125,000 BTU/h models); Titan tubes (150,000 to 200,000 BTU/h models) .

NOTE: Refer to the Tube Heater General Manual, Chart 3.6 (page 23) for secured reflector joints.

3.0 Operation

⚠ WARNING



This heater must be installed and serviced by trained gas installation and service personnel only.

Do not bypass any safety features or the heater's built in safety mechanisms will be compromised.

Note: Reference the Tube Heater General Manual for installation requirements.

Sequence of Operation

Starting Circuit: Upon a call for heat, the fan is energized. Once operational static pressure is achieved, the differential switch will close initiating the ignition sequence. After a 5-second delay, the glo-bar is energized for 45 seconds and the control allows the gas valve to open.

The trial for ignition is 8 seconds. If flame sense is not established within 8.5 seconds, the heater will attempt two (2) additional ignition sequences before proceeding to soft lockout. Soft lockout automatically retries after one (1) hour or the control can be reset by briefly interrupting the power source.

Running Circuit: After ignition, the flame rod monitors burner flame. If sense of flame is lost, the control immediately acts to reignite the gas-air mixture (identical to the starting sequence). If flame sense is not established within 8.5 seconds, the heater will attempt two (2) additional ignition sequences before proceeding to soft lockout. The control can be reset by briefly interrupting the power source.

Thermostat

NOTE: Different thermostats operate according to their particular features. Refer to thermostat specifications for details. Refer to Figure 2.1 for field wiring diagrams.

DX3 Series heaters with 24VAO option require a 24VAC, single-stage thermostat to operate. The burner control box is equipped with a round terminal strip that accepts two (2) 1/4" female spade terminals. Do not supply 120VAC to the 24VAC connection.

Diagnostics

Lockout:

The controls will automatically lockout the heater system when an external or system fault occurs. There are two types of lockout:


Soft Lockout: The heater will attempt to light three times. In the event of a failed attempt to light, (gas pressure, valve, no flame sense etc.), the heater will enter a soft lockout period for 15 minutes and then attempt to light three more times before entering Hard Lockout mode.

Hard Lockout: If proof of flame is not established, a component failure occurs or blockages are evident, the heater will enter hard lockout. If lockout occurs, the control can be reset by briefly interrupting the power source. Refer to Chart 3.1 below for a description of LED codes.


Operational Indicator Lights

The externally located operational indicator lights are provided to assist in troubleshooting of the heater. Refer to the following pages for additional troubleshooting.

Figure 3.1 • **Operational Indicator Lights**




4.0 Troubleshooting Guide





Continued on page 16.

NOTICE Bypassing any switch is intended for testing purposes only. Do not leave switch bypassed during normal operation or the heater's built-in safety mechanisms will be compromised.



Continued from page 14




Were the gas lines purged of air?
Yes
Confirm manifold pressure is correct and/or gas orifice is not plugged and is the correct size.
No
Purge gas line.
Is the heater properly grounded? Is the heater's polarity correct?
Yes
With micrometer, check amperage at flame rod. Is it greater than 1.0 microamps?
Yes
Check to make sure flame sensor wire is OK. If so, then replace circuit board.
No
Correct problem.
No
Sensing rod is faulty or flame is weak. Check to make sure heater is operating at proper gas pressure as indicated on burner rating plate and then, if needed, replace sensing rod.

5.0 Parts

Figure 5.1 • **Burner Assembly Components**





Chart 5.1 • **Parts List**

Part #	Description	Part #	Description
TP-5	Flange Gasket	TP-70	1/2” x 10” Control Box Gasket
TP-9	3/4” E.M.T. Conduit Coupling	TP-70A	1” x 6” Manifold Gasket
TP-10A	3/4” x 4” E.M.T. Conduit	TP-76	Rubber Grommet
TP-14	Sight Glass Gasket	TP-82	Reflector Center Support (RCS)
TP-15	Sight Glass	TP-83	1/2” x 24” C.S.S.T. Flexible Gas Connector
TP-16	Sight Glass Washer	TP-84	1/2” N.P.T (Female) to Male Flare Fitting
TP-17	Sight Glass Kit	TP-85	1/2” N.P.T. (Male) to Male Flare Fitting
TP-19B	4” Wire Hanger with Tension Spring	TP-105	Aluminum Reflector End Cap
TP-20C	10 ft. Polished Aluminum Reflector	TP-106	Reflector End Cap Clips (8 pcs.)
TP-20D*	120 in. Stainless Steel Reflector	TP-113	Reflector Tension Spring
TP-21B	4” Standard Tube Clamp	TP-200A	Low Burner (Blue)
TP-25*	1/4” Female Spade Terminal (Qty. 2)	TP-201B	Burner (Tan)
TP-26A	10 ft. Aluminized Radiant / Combustion Tube	TP-204	Gas Orifice (consult factory)
TP-26B	10 ft. Titanium Stabilized Combustion Tube	TP-205	Glo-Bar™ Holder
TP-26D*	10 ft. 304 Stainless Steel Radiant Tube	TP-212	1/2” N.P.T. x 3” Pipe Nipple
TP-26E*	10 ft. 409 Stainless Steel Combustion Tube	TP-217	1/8” N.P.T. Brass Barb Fitting
TP-31D	Interlocking Mounting Bracket (Qty. 2)	TP-219	12” Pneumatic Tube for Pressure Switch
TP-50	Glo-Bar™ Igniter	TP-220	Stainless Steel Tube Clamp (175 & 200 MBH)
TP-55A	Fan Blower	TP-221	Glo-Bar™ Holder Gasket
TP-65I	3 ft. Interlocking Turbulator Baffle	TP-222	Flame Rod
TP-68B	1/2” Strain Relief Bushing	TP-245	1/8” Plastic N.P.T. 90° Barb Fitting

* Optional upgrade or add-on item.

Figure 5.2 • **Tube & Reflector Components**









Part No.	Description	Part No.	Description
TP-264D	Differential Pressure Switch, 60 to 75 MBH	TP-3005A	Plastic Valve Chamber Lid
TP-264E	Differential Pressure Switch, 50 MBH	TP-3008A	Gas Valve Mounting Bracket
TP-264F	Differential Pressure Switch, 150 to 200 MBH	TP-3010	Service Panel Hinge
TP-321	Ignition Plate Gasket	TP-3011	Igniter Box
TP-328	120VAC Yellow Indicator Light (Qty. 2)	TP-3012	Igniter Box Cover
TP-329*	1/4" Male Spade Terminal Block	TP-3014	Plastic Air Orifice with Screen
TP-331	Green Self-Tap Ground Screw (Qty. 2)	TP-3033D*	Power Entry Plate*
TP-332	1/4" Divider Grommet	TP-3033E	DX3 Power Entry Plate
TP-333	6 ft. Black Power Cord w/ Ground	TP-3040	Gas Valve - Natural Gas
TP-351A	Potted Circuit Board	TP-3041	Gas Valve - LP Gas
TP-352A	Wire Harness for Ignition Controller	TP-3044	Gas Manifold
TP-383	Glo-Bar™ Igniter Plate	TP-3060	Pressure Switch Mounting Bracket
TP-579	4" Wire Hanger w/o Tension Spring	TP-3070	Low BTU Burner (Color Code - RED)
TP-832*	Thermostat Terminal Strip	TP-3071	High BTU Burner (Color Code - PURPLE)
TP-1018	20" Pneumatic Tube for Pressure Switch	TP-3093	#8-23 Cage Nut (Qty. 4)
TP-1264A	Differential Pressure Switch, 100 to 125 MBH	TP-3094A	#8-32 x ½" Metal Thumb Screw (Qty. 4)
TP-1325*	24V Coil Relay	TP-3096A	Valve Compartment Bottom Panel
TP-3001	Divider Panel	TP-3097A	Valve Compartment Top Panel
TP-3002A	Plastic End Panel, Control Compartment	TP-3098	Valve Compartment Side Panel
TP-3003A	Plastic End Panel, Fan Compartment	TP-3099	Controls Mounting Panel
TP-3004	Control Box	TP-3380	16" HSI Burner Tube w/Flange and Fittings

* Optional upgrade or add-on item.

Kit Contents Check List

Chart 5.2 • **Kit Contents for DX3 Series -** Reference the length column for your model.

DX3 Series Kit Contents			
TP-19B 4" Hanger with Reflector Tension Spring  ****TP-19C**	**TP-82** 4" Reflector Center Support (RCS)  ****TP-829**	**TP-105** Reflector End Cap  ****TP-105A**	**TP-106** Reflector End Cap Clips 
TP-83 24" Stainless Steel Flexible Gas Connector  ****TP-83A**	**TP-21B** 4" Tube Clamp  ****TP-220**	**LIOGT3** Tube Heater General Manual 	**LIODX3** DX3 Series Insert Manual 

Part No.	Description	20 ft.	30 ft.	40 ft.	50 ft.	60 ft.	70 ft.	80 ft.
TP-19B	4" Hanger w/ Tension Spring	3	4	5	6	7	8	9
TP-21B	4" Tube Clamp	2	3	4*	5*	6*	7*	8*
TP-82	4" Reflector Center Support	2	3	4	5	6	7	8
TP-83	24" S.S. Flexible Gas Connector	1	1	1	1	1	1	1
TP-105	Reflector End Cap	2	2	2	2	2	2	2
TP-106	Reflector End Cap Clips	8	8	8	8	8	8	8
LIOGT3	General Tube Heater Manual	1	1	1	1	1	1	1
LIODX3	DX3 Series Insert Manual	1	1	1	1	1	1	1
Additional kit contents as supplied when heater is configured with Add-On Options (if applicable)								
TP-25	1/4" Female Spade Terminal (24VAO)	2	2	2	2	2	2	2
Filled By:								

* **NOTE:** One 4" stainless steel tube clamp (P/N: TP-220) is provided for each 175,000 - 200,000 BTU model. Place as shown on page 11.

** Part number for models upgraded with stainless steel options.

Approvals

- CSA.
- Indoor approval.
- Outdoor approval with OD-Kit.
- Commercial approval.

Limited Warranty

- 1 year - Burner box components.
- 5 years - Combustion and radiant tubes.
- 10 years - Stainless steel burner.
- See page 36 of the General Tube Heater Manual for terms and conditions.

© 2012 Detroit Radiant Products Co.
21400 Hoover Road • Warren, MI 48089
Phone: (586) 756-0950 Fax: (586) 756-2626
www.detroitradiant.com • sales@drp-co.com